

BACnet protocol implementation conformance statement

Corrigo controller series





Company Information

Ever since its foundation in 1947, AB Regin has developed products and systems for creation of indoor comfort. Today, Regin is an important player with one of the market's broadest ranges of building automation and the knowledge, experience and resources to provide first-class support and guidance. Often considered the challenger in building automation, Regin continues to stand out through its undivided commitment and motivation to provide the best for customers and partners.

Further information on AB Regin can be found online at www.regincontrols.com.

Product description

Corrigo is a flexible controller with several communication ports that comes pre-loaded with an application which can easily be configured using Regin's downloadable software E tool[©].

Date October 10, 2013

Vendor name AB Regin

Vendor ID 264

Product name Corrigo

Product model number E151W-3, E151DW-3, E152DW-3, E281DW-3, E281DW-3,

E282W-3, E282DW-3, E283W-3, E283DW-3

Application software version -

Firmware revision 3.0.8.0264

BACnet protocol revision 1.9

BACnet Standardized Device Profile (Annex L)

☐ BACnet Operator Workstation (B-OWS)
☐ BACnet Advanced Operator Workstation (B-AWS)
□ BACnet Operator Display (B-OD)□ BACnet Building Controller (B-BC)
☐ BACnet Advanced Application Controller (B-AAC) ☐ BACnet Application Specific Controller (B-ASC)
☐ BACnet Smart Sensor (B-SS)

List of all BACnet Interoperability Building Blocks Supported (Annex K)

	Data Sharing – ReadProperty-B	DS-RP-B
Data sharing	Data Sharing – ReadPropertyMultiple-B	DS-RPM-B
	Data Sharing – WriteProperty-B	DS-WP-B
	Device Management – Dynamic Device Binding-B	DM-DDB-B
Device Management	Device Management – Dynamic Object Binding-B	DM-DOB-B
	Device Management – DeviceCommunicationControl-B	DM-DCC-B
	Device Management – TimeSynchronization-B	DM-TS-B

Segmentation Capability

☐ Able to transmit segmented messages	Window Size:
☐ Able to receive segmented messages	Window Size:

Standard Object Types Supported

Object type	Supported	Creatable	Deleteable
Analog Input	•		
Analog Output			
Analog Value	•		
Binary Input	•		
Binary Output			
Binary Value	•		
Calendar			
Command			
Device	•		
Event Enrollment			
File			
Group			
Loop			
Multi-State Input	•		
Multi-State Output			
Multi-State Value	•		
Notification Class			
Program			
Schedule			
Averaging			
Trend Log			
Life Safety Point			
Life Safety Zone			
Accumulator			
Pulse Converter			

Object type	Optional properties supported	Writeable properties (not otherwise required by the standard)	Range restrictions
A a la l	Description		
Analog Input	Reliability		
Analas Value	Present_Value	Writeable	
Analog Value	Description		
	Description		
Din amalamat	Reliability		
Binary Input	Inactive_Text		
	Active_Text		
	Present_Value	Writeable	
	Description		
Binary Value			
	Inactive_Text		
	Active_Text		
	Location	Writeable	
	Description	Writeable	
Device	Local_Time		
	Local_Date		
	Description		
Multistate Input	Reliability		
Прис	State_Text		
Multistate	Present_Value	Writeable	
	Description		
Value	Reliability		
	State_Text		

Data Link Layer Options

☑ BACnet IP, (Annex J)		
☑ BACnet IP, (Annex J), Foreign Device		
☐ ISO 8802-3, Ethernet (Clause 7)		
☐ ATA 878.1, 2.5 Mb. ARCNET (Clause 8)		
☐ ATA 878.1, EIA-485 ARCNET (Clause 8), baud rate(s)		
☐ MS/TP master (Clause 9), baud rate(s) :		
☐ MS/TP slave (Clause 9), baud rate(s) :		
☐ Point-To-Point, EIA 232 (Clause 10), baud rate(s):		
☐ Point-To-Point, modem, (Clause 10), baud rate(s):		
☐ LonTalk, (Clause 11), medium:		
☐ BACnet/ZigBee (ANNEX O)		
☐ Other:		
Barta Allara Bhallan		
Device Address Binding		
Is static device binding supported? (This is currently necessary for two-wa certain other devices.) ☐ Yes ☑ No	y communication with N	IS/TP slaves and
Networking Options		
☐ Router, Clause 6 - List all routing configurations, e.g., ARCNET-Etherne	t, Ethernet-MS/TP, etc.	
☐ Annex H, BACnet Tunneling Router over IP		
☐ BACnet/IP Broadcast Management Device (BBMD)		
Does the BBMD support registrations by Foreign Devices?	☐ Yes	□ No
Does the BBMD support network address translation?	☐ Yes	□ No
Network Security Options		
☑ Non-secure Device – is capable of operating without BACnet Network Secure Device De	ecurity	
☐ Secure Device – is capable of using BACnet Network Security (NS-SD E	BIBB)	
☐ Multiple Application-Specific Keys:		
☐ Supports encryption (NS-ED BIBB)		
☐ Key Server (NS-KS BIBB)		

Character Sets Supported

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.			
☑ ISO 10646 (UTF-8)	☑ IBM [™] /Microsoft [™] DBCS	□ ISO 8859-1	
☑ ISO 10646 (UCS-2)	☐ ISO 10646 (UCS-4)	☐ JIS X 0208	
If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:			
N/a			



